

Mast range

HEB profiles 160-200 / 200-240

Note

Wall bolt 1441

Wall bolt pair 1442

H = according to local conditions

Assembly of Insulating set not possible

The static proof for the mast bracket and the indication of the effect on the structure are required in any case.
The proof of the wall bolts is provided by the customer.

Drawing number

317.00047, .00047-6

Ordering information

for HEB 180

1411.18 Mast connection to sloping wall

